

WOOD PAINT SYSTEM: 1 COAT OF DUNN-EDWARDS ULTR-GRIP PREMIUM, AT 3-4 MILS, OR EQUAL, FOLLOWED BY TWO COATS OF EVERSIELD ULTRA-PREMIUM EXTERIOR PAINT AT 3-4 MILS, OR EQUAL
STUCCO PAINT SYSTEM: 1 COAT OF DUNN-EDWARDS EFF-STOP PREMIUM AT 3-4 MILS, OR EQUAL, FOLLOWED BY TWO COATS OF EVERSIELD ULTRA-PREMIUM EXTERIOR PAINT AT 3-4 MILS, OR EQUAL
METAL PAINT SYSTEM: HAND TOOL CLEAN SSPC-11, THEN SPOT PRIME ALL RUSTED AREAS USING DEVOE'S 231 EPOXY AT 3-4 MILS D.F.T. OR EQUAL AND APPLY TWO FULL COATS OF DEVOE'S 379 POLYURETHANE ENAMEL AT 2-3 MILS D.F.T., OR EQUAL

REMOVE AND REINSTALL
ROOFING SYSTEM. NEW ROOFING TO
INCLUDE SELF ADHERING TILE
UNDERLAYMENT, AND BIRD STOP
FLASHING

PRIME AND PAINT ALL INTERIOR
AND EXTERIOR WOOD MEMBERS
AND STUCCO

SPOT PRIME AND PAINT ALL
METAL BARS, LOUVERS, AND
GUTTER SYSTEM







SEVERE DRY ROT
INSIDE AND OUTSIDE
BUILDING


SPOT PRIME AND PAINT ALL
METAL BARS

REMOVE, REINSTALL AS
REQUIRED FOR THE
WORK. PRIME AND PAINT





SEVERE DRY ROT
INSIDE AND OUTSIDE
BUILDING



PAINT METAL
DOORS AND
LOUVERS


SPOT PRIME AND PAINT ALL
METAL BARS

PRIME AND PAINT STUCCO



PRIME AND PAINT ALL NEW AND
EXISTING WOOD ON PUMP
HOUSE BUILDING

SPOT PRIME AND PAINT ALL
METAL BARS





SEVERE DRY ROT
INSIDE AND OUTSIDE
BUILDING



PRIME AND PAINT ALL NEW AND
EXISTING WOOD ON PUMP
HOUSE BUILDING

SPOT PRIME AND PAINT METAL
ELECTRICAL CABINET

SEVERE DRY ROT
INSIDE AND OUTSIDE
BUILDING



