



CUT IN CONNECTION BY CONTRACTOR
 1-16" PVC TO ACP TRANSITION COUPLING
 1-3' MIN. OF 16" PVC SPOOL (PEXPE)
 1-16"x8" REDUCER (MJXF)
 1-8" DI 90° BEND (FXMJ)
 1-16"x8" RED. THRUST BLOCK (A=28.0SF)
 1-8" 90° BEND THRUST BLOCK (A=14.0SF)

CUT IN CONNECTION BY CONTRACTOR
 1-8" GV (MJXF)
 1-8" DI 90° BEND (FXF)
 1-16"x8" REDUCER (FXMJ)
 1-3' MIN. OF 16" PVC SPOOL (PEXPE)
 1-16" PVC TO ACP TRANSITION COUPLING
 1-16"x8" RED. THRUST BLOCK (A=28.0SF)
 1-8" 90° BEND THRUST BLOCK (A=14.0SF)